



Installation 1

Location: Before the heat exchanger of the first cooling water system
 Pipe size: 80 mm
 Model: S25
 Result: After 2 months, the heat exchanger was opened. It was found that the scale on the wall of the heat exchanger became muddy and easy to clean.



Vulcan S25 was installed in front of the heat exchanger for the cooling water pipe

Installation 2

Location: Before the heat exchanger of the second cooling water system
 Pipe size: 100 mm
 Model: S100
 Result: The water cooling system keeps running stably. It is not necessary to clean the scale every 2 months like before anymore.



Vulcan S100 was installed in front of the heat exchanger for the cooling water pipe

Without Vulcan



Before installing Vulcan, the scale was very thick and hard in the heat exchanger tubes.

After installing Vulcan for 2 months



The scale becomes soft and muddy.